File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Application No
Permit No.

(1) OWNER: Name Big Gibs Address Republic

LOCATION OF WELL: County Ferry SW¼ NE¼ Sec. 5 T 36 N., R 32 W.M.
ng and distance from section or subdivision corner 33

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one)
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled ft. Depth of completed well 95 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from +1 ft. to 90 ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☒ No ☐
Manufacturer's Name Well Strainer
Type Stainless Model No. 204
Diam. 5 Slot size 14 from 90 ft. to 95 ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? 19 ft.
Material used in seal Bentinite CLAY
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 12 ft. below top of well Date
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☐ If yes, by whom?
Yield: 30 gal./min. with ft. drawdown after hrs.
" EST. AIR LIFT " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☐

2/6/85 RD

(10) WELL LOG:
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL			FROM	TO
ROCK	Fill		0	7
SAND & CLAY		gray	7	34
SAND	Fine	Brown	34	100
SAND & GRAVEL		Brown	100	105

Work started 10/15 19 84 Completed 1/11 19 85

WELL DRILLER'S STATEMENT:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Eagle Pump (Person, firm, or corporation) (Type or print)
Address 316 W 5th Colville
[Signed] William B Davis (Well Driller)
License No. 1356 Date 1/11 19 84