

9 BATHUA

# WATER WELL REPORT

State of Washington Date Printed: 15-Apr-2008 Log No. 0  
Construction / Decommission: Original Construction Construction Notice

CURRENT  
Notice of Intent No. WEO7895  
Unique Ecology Well I.D. No. BAB683  
Water Right Permit Number:

OWNER: NICHOLAS, ROBERT  
OWNER ADD P O BOX 750  
KETTLE FALLS, WA 99141

**PROPOSED USE: DOMESTIC**

**TYPE OF WORK:** Owners's Well Number: (If more than one well)  
**NEW WELL** Method: **ROTARY**

**DIMENSIONS** Diameter of well: 6 inches  
Drilled 120 ft. Depth of completed well 120 ft.

**CONSTRUCTION DETAILS:** Casing installed **WELDED**  
Liner installed: **PVC** 6 " Dia from +2 ft. to 18 ft.  
4 " Dia from 10 ft. to 120 ft. " Dia from ft. to ft.

**Perforations:** Yes Used In: **LINER**  
Type of perforator used **SKILL SAW**  
SIZE of perforations 1/8 in. b 6 in.  
90 Perforation from 60 ft. to 120 ft.  
Perforation from ft. to ft.  
Perforation from ft. to ft.

**Screens:** No K-Pac Location  
Manufacture's Name  
Type: Model No  
Diam. slot size from ft. to ft.  
Diam. slot size from ft. to ft.

**Gravel/Filter packed:** No Size of Gravel  
Material placed fro ft. to ft.

**Surface seal:** Yes To what depth 18 ft.  
Seal method: Material used in seal **BENTONITE**  
Did any strata contain unusable water No  
Type of water Depth of strata  
Method of sealing strata off

**PUMP:** Manufacture's name  
Type: H.P. 0

**WATER LEVELS** Land-surface elevation above mean sea level: 0 ft.  
Static level 40 ft. below top of well Date 03/21/2008  
Artesian Pressure lbs per square inch Date  
Artesian water controlled by


Well Add 34135 HIGHWAY 20 EAST  
City: Kettle Falls, WA 99141 County: FERRY  
Location: NW 1/4 NE 1/4 Sec 15 T 36 R 37E EW  
Lat/Long: Lat Deg Lat Min/Sec  
(s, t, r still REQUIRED) Long Deg Long Min/Sec  
Tax Parcel No.: 73615110003005


**CONSTRUCTION OR DECOMMISSION PROCEDURE**  
Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOP SOIL	0	2
SANDY CLAY GRAVEL COBBLES	2	13
HARD GRANITE GNEISS	13	35
FRACTURED W/VOIDS	35	40
GNEISS	40	70
FRACTURED W/WATER	70	75
HARD GNEISS	75	120

Notes:  
Work starte 03/19/2008 Complete 03/21/2008

**WELL CONSTRUCTION CERTIFICATION:**  
I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.  
 Driller  Engineer  Trainee

Name: **SAM BEARDSLEE** License No.: 2905T  
Signature: 

If trainee, Licensed driller is: **RONALD HURN** License No.: 2258  
Licensed Driller Signature: 

**WELL TESTS:** Drawdown is amount water level is lowered below static level.  
Was a pump test made No If yes, by whom  
Yield  gal/min with  ft drawdown after  
Yield  gal/min with  ft drawdown after  
Yield  gal/min with  ft drawdown after  
Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)  
Time: Water Level Time: Water Level Time: Water Level  
       
Date of test:  
Bailer test gal/min ft drawdown after hrs.  
Air test 10 gal/min w/ stem set at 120 ft. for 1 hours  
Artesian flow gpm Date  
Temperature of water Was a chemical analysis made No

**Drilling Company:**  
NAME: **FOGLE PUMP & SUPPLY, INC.** Shop: **COLVILLE**  
ADDRESS: 316 W. 5TH  
Colville, WA 99114  
Phone: 509-684-2569 Toll Free: 800-533-6518  
E-Mail: [jeanne@foglepump.com](mailto:jeanne@foglepump.com)  
FAX: 509-684-3032 WEB Site: [www.foglepump.com](http://www.foglepump.com)  
Contractor's  
Registration No.: **FOGLEPS095L4** Date Log Created: 03/26/2008

Well ID# BAB 683

Phone 738-2870

738 3390

# Fogle Pump & Supply, Inc.

## Customer Pump & System Record

OWNER

Name ROBERT NICHOLAS / JON VANSOEST Date 5-7-08

Address P 34135 Hwy 20 K.F.

Well Billing Address P.O. Box 750 KETTLE FALLS

Legal Description 1/4 1/4 SECT T R

Water Use, Domestic X Irrigation        Subdivision        Other       

Well Depth 120 ID 6x4 1/2 in GPM 10 Static       

Pump Brand GOULDS BALANCE FLOW SYSTEM (New) - Used

Pump Model # 106510 GPM 10 PSI 50

Pump Serial # 00824605 Date Code 07

Motor Brand FRANKLIN New - Used

Motor HP 1 Volts 230 Phs 3

Motor Serial #        Date Code 07

Warranty #        5 yr. Y 1 yr.        None       

Pump Protector Type INTERNAL Brand        Model       

Tank Brand In well PANEL BOARD LATER Model SKINNY Warranty        yrs.

Pump Setting 100' pi Pipe Size 1" Pipe Type SCH 120

Wire in well Size #12-4 Type SUB

Pitless Size 1" PA Brand DICKENS

Well House        Pit        Other, Explain       

Distance to House 80' Elevation        Pipe Size & Type       

Distance to Power Supply 80' Wire Size & Type #12 THW

Location of Control BF-20 BF 120 STOP LATER NEXT TO PERISTAL

### WARNING

AVOID SERIOUS OR FATAL SHOCK BY QUALIFIED PERSONNEL COMPLYING WITH ALL GROUNDING AND CODE REQUIREMENTS.

THIS LABEL IDENTIFIES THE FRANKLIN SUBMERSIBLE MOTOR USED IN THE WELL. PLEASE DISPLAY PROMINENTLY. A SUGGESTED LOCATION IS THE DISCONNECT BOX.

MODEL 2345139203 HP 1 KW 0.75 PH 3  
VOLTS 230 RPM 3450 HZ 60  
AMP 3.9 S.F. MAX. AMP 4.7  
SF 1.4 KVA CODE M CONT. DUTY  
CSA CERTIFIED

Installed By BOONE

Electrical By       

7-14-08 MOUNTED BF-20  
NEXT TO PERISTAL BY  
NEW HOUSE ? INSTALLED  
SKINNY IN WELL TANK  
BS

Invoice #       

