

Well ID# AHB-540

Phone 360-944-9098

Fogle Pump & Supply, Inc.

Customer Pump & System Record

Acc 1-18-06

Name Pat Hogue Date 10-31-02

Address Marble Flats Northport

Well Billing Address 9213 N.E. Pietz, Vancouver WA 98664

Legal Description _____ 1/4 _____ 1/4 SECT _____ T _____ R _____

Water Use, Domestic Irrigation Subdivision _____ Other _____

Well Depth 180' ID 6" GPM 70-80 Static _____

Pump Brand Accumotor New - Used

Pump Model # A420-200 GPM _____ PSI _____

Pump Serial # 05758 Date Code K2-98

Motor Brand Franklin New - Used

Motor HP 2 Volts 230 Phs 3

Motor Serial # 05-2325 Date Code 02C18

Warranty # _____ 5 yr. 1 yr. _____ None _____

Pump Protector Type None Brand _____ Model _____

Tank Brand WELUMATE Model WM-6 Warranty 5 yrs.

Pump Setting 165' pipe Pipe Size 1 1/4" Pipe Type Sch 80 pipe

Wire in well Size #10-4 Type sub

Pitless Size 1 1/4" Brand Baker

Well House _____ Pit _____ Other, Explain _____

Distance to House 100' Elevation 2 Pipe Size & Type 1 1/4" + 1" Sch 40 pipe


Distance to Power Supply 80' Wire Size & Type #10-4 sub

Location of Control pump house

Drilled By Fogles Installed By SP Fogles

Dug By Fogles Electrical By GREG SON BRAND

Comments: SEE BACK NEW PUMP



SUPERTECTION™

POLICY A-
NUMBER No 135972

4-21-03
INSTALLED PRESSURE TANK, WIRING
PUMP HOUSE INSTALLED
CYCLE STOP

Invoice # 261180