

95564

WATER WELL REPORT

Notice of Intent W128017

Date Printed 14-Nov-2000

Unique Well I D No AFQ870

Log No J

State of Washington

Water Right Permit Number

(1) OWNER **SCHMALENBERG, JOHN** Address **PO BOX 44017 Tacoma, WA 98444**

(2) LOCATION OF WELL County **OKANOGAN** SW 1/4 NW 1/4 Sec 1 T 35 R 30E WM

(2a) Street Address of well **CABINET RD**

Tax Parcel No

E

(3) PROPOSED USE **DOMESTIC**

(4) TYPE OF WORK Owners' Number of well
NEW WELL (If more than one well) 1

(10) Well Log

Date 11/14/2000 Method **ROTARY**

Formation Describe by color, character, size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated Show at least one entry for each change in formation

(5) DIMENSIONS Diameter of well 6 inches
Drilled 340 ft Depth of completed well 340 ft

(6) CONSTRUCTION DETAILS Casing installed **WELDED**

Material	From	To
LOAM BROWN	0	1
GRANITE GRAY BROKEN	1	9
QUARTZ WHITE GRANITE	9	42
GRAY SOFT	42	42
QUARTZ WHITE BROKEN	42	45
W/WATER	45	45
GRANITE GRAY PERIODIC	45	91
QUARTZ WHITE MEDIUM SOFT	94	94
QUARTZ WHITE BROKEN	94	100
GRANITE GRAY QUARTZ	100	208
WHITE MEDIUM	208	208
QUARTZ WHITE BROKEN	208	215
W/WATER	215	215
GRANITE GRAY QUARTZ	215	340
WHITE MEDIUM	340	340

Liner installed 6" Dia from +2 ft to 18 ft
" Dia from ft to ft
4" Dia from 8 ft to 340 ft " Dia from ft to ft

Perforations used? Yes Used In Liner

Type of perforator used **SKILL SAW**

SIZE of perforations 1/8 in by 7 in

70 Perforations from 180 ft to 220 ft

70 Perforations from 300 ft to 340 ft

Perforations from ft to ft

Screens No K-Pac Location

Manufacture's Name

Type Model No

Diam slot size from ft to ft

Diam slot size from ft to ft

Gravel packed No Size of Gravel

Gravel placed from ft to ft

Surface seal Yes To what depth 18 ft

Seal method Material used in seal **BENTONITE**

Did any strata contain unusable water? No

Type of water Depth of strata

Method of sealing strata off

Notes

(7) PUMP Manufacture's name

Type H P 0

(8) WATER LEVELS Land-surface elevation above mean sea level 0 ft

Static level 40 ft below top of well Date 09/27/2000

Artesian Pressure lbs per square inch Date

Artesian water controlled by

Work started 09/26/2000

Completed 09/27/2000

(9) WELL TESTS Drawdown is amount water level is lowered below static level

WELL CONSTRUCTION CERTIFICATION

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

JON RICARD

License No 2341

(Driller/Licensed Engineer)

Was a pump test made? No If yes by whom

Yield gal/min with ft drawdown after

Trainee Name

License No

NAME **FOGLE PUMP & SUPPLY, INC**

Shop **COLVILLE**

ADDRESS **316 W 5TH**

Colville, WA 99114

Recovery data

Time Water Level

Test Date

Phone **509-684-2569**

Toll Free **800-533-6518**

Bailer test gal/min ft drawdown after hrs

E-Mail

Air test 1 gal/min w/ stem set at 340 ft for 15 hours

FAX **509-684-3032**

WEB Site **www.foglepump.com**

Artesian flow gpm Date

[SIGNED] *Jon Ricard*

License No 2341

Temperature of water Was a chemical analysis made No

Contractor's

(Driller/Licensed Engineer)

Registration No **FOGLEPS095L4** Date Log Created **11/14/00**

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.