

WATER WELL REPORT

State of Washington Date Printed: **06-Feb-2006** Log No. **54905**
 Construction / Decommission: Original Construction Notice

CURRENT
 Notice of Intent N **W232053**
 Unique Ecology Well I.D. No **APN381**
 Water Right Permit Number:
 OWNER: **RUSHTON, CYNTHIA**
 OWNER ADD **PO BOX 144**
INCHELIUM, WA 99138
 Well Add **423 SEYLOR VALLEY RD**
 City: **Inchelium, WA 99138** County: **Ferry**
 Location: **NW 1/4 SE 1/4 Sec 21 T 33 R 36E EW**
 Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still) Long Deg Long Min/Sec
 REQUIRED)
 Tax Parcel No.: **6.33.21.31.00010.02**

| | |
|---|---|
| PROPOSED USE: DOMESTIC | |
| TYPE OF WORK: Owners's Well Number: (If more than one well) 01 NEW WELL Method: ROTARY | |
| DIMENSIONS Diameter of well: 6 inches Drilled 380 ft. Depth of completed well 380 ft. | |
| CONSTRUCTION DETAILS: | Casing installed WELDED |
| Liner installed: | 6 " Dia from +2 ft. to 298 ft. |
| " Dia from ft. to ft. | " Dia from ft. to ft. " Dia from ft. to ft. |
| Perforations: No Used In: Type of perforator used SIZE of perforations in. b in. Perforation from ft. to ft. Perforation from ft. to ft. Perforation from ft. to ft. | |
| Screens: No K-Pac Location Manufacture's Name Type: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft. | |
| Gravel/Filter packed: No Size of Gravel Material placed fro ft. to ft. | |
| Surface seal: Yes To what depth 19 ft. Seal method: Material used in seal BENTONITE Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off | |
| PUMP: Manufacture's name Type: H.P. 0 | |
| WATER LEVELS Land-surface elevation above mean sea level: 0 ft. Static level 15 ft. below top of well Date 11/03/2005 Artesian Pressure lbs per square inch Date Artesian water controlled by | |
| WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield <input type="text"/> gal/min with <input type="text"/> ft drawdown after <input type="text"/> Yield <input type="text"/> gal/min with <input type="text"/> ft drawdown after <input type="text"/> Yield <input type="text"/> gal/min with <input type="text"/> ft drawdown after <input type="text"/> <i>Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level</i> Time: Water Level Time: Water Level Time: Water Level <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> <input type="text"/> Date of test: Bailer test gal/min ft drawdown after hrs. Air test 100 gal/min w/ stem set at 379 ft. for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No | |

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

| Material | From | To |
|--------------------------|------------|------------|
| TOP SOIL | 0 | 1 |
| SAND BROWN | 1 | 8 |
| SANDY BROWN CLAY | 8 | 30 |
| SANDY BROWN MOIST | 30 | 86 |
| GRAY SILTY CLAY | 86 | 295 |
| CEMENTED GRAVEL | 295 | 322 |
| GRAY HARDPAN CLAY | 322 | 323 |
| GRAVEL W/WATER | 323 | 380 |

Notes:

Work starte **10/31/2005** Complete **11/03/2005**

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee

Name: **ANDREW BAKER** License No.: **2751T**

Signature:

If trainee, Licensed driller is: **RONALD HURN** License No.: **2258**

Licensed Driller Signature:

Drilling Company:
 NAME: **FOGLE PUMP & SUPPLY, INC.** Shop: **COLVILLE**
 ADDRESS: **316 W. 5TH**
Colville, WA 99114
 Phone: **509-684-2569** Toll Free: **800-533-6518**
 E-Mail: **jrs@foglepump.com**
 FAX: **509-684-3032** WEB Site: **www.foglepump.com**
 Contractor's
 Registration No.: **FOGLEPS095L4** Date Log Created: **11/19/2005**