

WATER WELL REPORT

State of Washington Date Printed: 09-Jun-2017 Log No. 0
Construction / Decommission: Original
Construction Construction Notice

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) 1
NEW WELL Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
Drilled 200 ft. Depth of completed well 200 ft.

CONSTRUCTION DETAILS: Casing installed WELDED
Liner installed: PVC
4 " Dia from 20 ft. to 200 ft. 6 " Dia from +2 ft. to 37 ft.
" Dia from ft. to ft.
" Dia from ft. to ft.

Perforations: Yes Used In: LINER
Type of perforator used SKILL SAW
SIZE of perforations 1/4 in. by 6 in.
90 Perforations from 140 ft. to 200 ft.
Perforations from ft. to ft.
Perforations from ft. to ft.

Screens: 0 K-Pac Location:
Manufacture's Name
Type: Model No
Diam. slot size: from ft. to ft.
Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel
Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.
Seal method: Material used in seal BENTONITE
Did any strata contain unusable water No
Type of water Depth of strata
Method of sealing strata off

PUMP: Manufacture's name
Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.

Static level 70 ft. below top of well Date 06/02/2017
Artesian Pressure lbs per square inch Date
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test: 6/2/2017
Bailer test gal/min ft drawdown after hrs.
Air test 4 gal/min w/ stem set at 200 ft. for 1 hours
Artesian flow gpm Date
Temperature of water Was a chemical analysis made No

CURRENT
Notice of Intent No.: WE27074
Unique Ecology Well I.D. No BJD288
Water Right Permit Number:
OWNER: OFFERDAHL, HANS

OWNER ADD 3417 RED MARBLE ROAD
CHEWELAH, WA 99109

Well Add 3417 RED MARBLE ROAD

City: Chewelah, WA 99109 County: Stevens
Location: NE 1/4 SE 1/4 Sec 10 T 31 R 39E EW
Lat/Long: Lat Deg Lat Min/Sec
(s, t, r still Long Deg Long Min/Sec
REQUIRED)
Tax Parcel No.: 2098535

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOPSOIL	0	2
SAND GRAVEL	2	16
SANDY CLAY	16	35
BROKEN ROCK	35	37
DK GRANITE	37	98
DK GRANITE W/WATER	98	100
HARD GRANITE	100	175
HARD GRANITE W/WATER	175	180
HARD DK GRANITE	180	200

RECEIVED

JUL 21 2017

Notes:

Department of Ecology
Eastern Regional Office

Work starts 06/01/2017 Complete 06/02/2017

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee

Name: BILLY SANDERS License No.: 3235T

Signature:

If trainee, Licensed driller is: DAVID MEYER License No.: 2427

Licensed Driller Signature

Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE

ADDRESS: 2250 NORTH HWY

Colville, WA 99114

Phone: 509-684-2569 Toll Free: 800-533-6518

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4 Date Log Created: 6/9/2017

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report