

WATER WELL REPORT

State of Washington Date Printed: 19-Aug-2008 Log No. 0
 Construction / Decommission: Original Construction Notice
 Construction

CURRENT
 Notice of Intent No.: WEO8690
 Unique Ecology Well I.D. No APE581
 Water Right Permit Number:
 OWNER: TRALLE, MARY

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) 1
NEW WELL Method: **ROTARY**

DIMENSIONS Diameter of well: 6 inches
 Drilled 120 ft. Depth of completed well 120 ft.

CONSTRUCTION DETAILS: Casing installed **WELDED**

Liner installed: PVC	6 " Dia from	+2 ft. to	58 ft.
4 " Dia from	20 ft. to	120 ft.	
	" Dia from	ft. to	ft.
	" Dia from	ft. to	ft.

Perforations: Yes Used In: **LINER**
 Type of perforator used **SKILL SAW**
 SIZE of perforations 1/4 in. b 6 in.

40	Perforation from	80	ft. to	120	ft.
	Perforation from		ft. to		ft.
	Perforation from		ft. to		ft.

Screens: No K-Pac Location
 Manufacture's Name
 Type: Model No
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel/Filter packed: No Size of Gravel
 Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.
 Seal method: Material used in seal **BENTONITE**
 Did any strata contain unusable water No
 Type of water Depth of strata
 Method of sealing strata off

PUMP: Manufacture's name
 Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.
 Static level 40 ft. below top of well Date 08/12/2008
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by

OWNER ADD P O BOX 3248
 SEQUIM, WA 98382
 Well Add 2558 GRIMM ROAD
 City: Addy, WA 99101 County: Stevens
 Location: SW 1/4 SE 1/4 Sec 3 T 32 R 38E EW
 Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still REQUIRED) Long Deg Long Min/Se
 Tax Parcel No.: 1792751

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.


Material	From	To
GLACIAL TILL	0	53
LIMESTONE GREY MED	53	92
BROKEN W/30 GPM	92	98
LIMESTONE BLACK VERY HARD	98	120

Notes:

Work starte 08/11/2008 Complete 08/12/2008

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee

Name: **DAVID MEYER** License No.: 2427
 Signature: 

If trainee, Licensed driller is: License No.:
 Licensed Driller Signature

Drilling Company:
 NAME: **FOGLE PUMP & SUPPLY, INC.** Shop: COLVILLE
 ADDRESS: 316 W. 5TH
 Colville, WA 99114
 Phone: 509-684-2569 Toll Free: 800-533-6518
 E-Mail: jeanne@foglepump.com
 FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's
 Registration No.: FOGLEPS095L4 Date Log Created: 08/18/200

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made No If yes, by whom

Yield	gal/min with	ft drawdown after	
Yield	gal/min with	ft drawdown after	
Yield	gal/min with	ft drawdown after	

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test:
 Bailer test gal/min ft drawdown after hrs.
 Air test 30 gal/min w/ stem set at 119 ft. for 1 hours
 Artesian flow gpm Date
 Temperature of water Was a chemical analysis made No