

Amended

WATER WELL REPORT

State of Washington Date Printed: 05-Oct-2017 Log No. 0
Construction / Decommission: Original
Construction Construction Notice W046972

CURRENT
Notice of Intent No.: WE25124
Unique Ecology Well I.D. No AAK007
Water Right Permit Number:
OWNER: CRIST, DAVID

PROPOSED USE: DOMESTIC

OWNER ADD 810 SOUTH CHESTER STREET
COLVILLE, WA 99114

TYPE OF WORK: Owners's Well Number: (If more than one well) 1
DEEPEMED Method: ROTARY

Well Add 842-U VALLEY WESTSIDE RD

DIMENSIONS: Diameter of well: 6 inches
Drilled 60 ft. Depth of completed well 280 ft.

City: Colville, WA 99114 County: Stevens
Location: SW 1/4 SW 1/4 Sec 20 T 35 R 39E EW
Lat/Long: Lat Deg Lat Min/Sec
(s, t, r still) Long Deg Long Min/Sec
REQUIRED)
Tax Parcel No.: 2258643

CONSTRUCTION DETAILS:
Liner installed: PVC
4 " Dia from 17 ft. to 280 ft.

Casing installed EXISTING
6 " Dia from +1 ft. to 59 ft.
" Dia from ft. to ft.
" Dia from ft. to ft.

Perforations: Yes Used In: LINER
Type of perforator used SKILL SAW
SIZE of perforations 1/8 in. by 7 in.
120 Perforations from 120 ft. to 280 ft.
Perforations from ft. to ft.
Perforations from ft. to ft.

Screens: 0 K-Pac Location:
Manufacture's Name
Type: Model No
Diam. slot size: from ft. to ft.
Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel
Material placed fro ft. to ft.

Surface seal: No To what depth ft.
Seal method: Material used in seal EXISTING
Did any strata contain unusable water No
Type of water Depth of strata
Method of sealing strata off

PUMP: Manufacture's name
Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.
Static level 95 ft. below top of well Date 08/24/2016
Artesian Pressure lbs per square inch Date
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made No If yes, by whom
Field: gal/min with ft drawdown after
Field: gal/min with ft drawdown after
Field: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)
Time: Water Level Time: Water Level Time: Water Level
Date of test: 8/24/2016
Pail test gal/min ft drawdown after hrs.
Pump test 12 gal/min w/ stem set at 279 ft. for 1 1/2 hours
Artesian flow gpm Date
Temperature of water Was a chemical analysis made No

CONSTRUCTION OR DECOMMISSION PROCEDURE
Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
EXISTING	0	220
S&P GRANITE BROKEN W/WATER 12 GPM	220	245
S&P GRANITE MED	245	265
S&P GRANITE HARD	265	280

RECEIVED
OCT 17 2017
Department of Ecology
Eastern Washington Office

Notes:
WELL CAVED IN @ 195 - 220, AIRTESTED @ 6 GPM AT 220

Work starte 08/23/2016 Complete 08/24/2016

WELL CONSTRUCTION CERTIFICATION:
I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee
Name: JON RICARD License No.: 2341
Signature:

If trainee, Licensed driller is: License No.:
Licensed Driller Signature

Drilling Company:
NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE
ADDRESS: 2250 NORTH HWY
Colville, WA 99114
Phone: 509-684-2569 Toll Free: 800-533-6518
E-Mail: jeanne@foglepump.com
FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's
Registration No.: FOGLEPS095L4 Date Log Created: 8/26/2016

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report