IF TRAINEE: Sponsor's License No.

Sponsor's Signature



ECOLOGY	Unique Ecology Well ID Tag No. BPC537		
Type of Work: Construction State of Washington	Site Well Name (if more than one well):		
☐ Decommission	Water Right Permit/Certificate No.		
Proposed Use: ■ Domestic □ Industrial □ Municipal	Property Owner Name MARC STRAUB		
☐ Dewatering ☐ Irrigation ☐ Test Well ☐ Other	Well Street Address 974 SKYWIEWAY		
Construction Type: Method:			
■ New well □ Alteration □ Driven □ Jetted □ Cable Tool □ Deepening □ Other □ Dug ■ Air- □ Mud-Rotary	City COLVILLE County STEVENS		
Dimensions: Diameter of boring 6 in., to 200 ft. □ Dug □ Air- □ Mud-Rotary in., to 200 ft.	Tax Parcel No. 2211401		
Depth of completed well 200 ft.	Was a variance approved for this well? ☐ Yes ■ No		
Construction Details: Wall	If yes, what was the variance for?		
Casing Liner Diameter From To Thickness Steel PVC Welded Thread 6 in. +2 22 0.25 in.	Location (see instructions on page 2): □ WWM or ■ EWM		
□ ■ <u>4</u> in. <u>10</u> 2 <u>00</u> <u>0.25</u> in. □ ■ □ □	NE ¼-¼ of the NW ¼; Section 28 Township 34N Range 39E		
	Latitude (Example: 47.12345) 48.420426		
	Longitude (Example: -120.12345) -117.904144		
Perforations: ■ Yes □ No Type of perforator used SKILSAW	ions: Yes No Type of perforator used SKILSAW Drillante Log/Construction on Decomplication Proceedings		
No. of perforations 165 Size of perforations 0.125 in. by 6 in. Perforated from 90 ft. to 200 ft. below ground surface	Formation: Describe by color, character, size of material and structure, and the kind and		
Screens: ☐ Yes ■ No ☐ K-Packer ➡ Depth ft.	nature of the material in each layer penetrated, with at least one entry for each change of information. Use additional sheets if necessary.		
Manufacturer's Name	Material	From	То
Type Model No	TOP SOIL	0	1
Diameter in. Slot size in. from ft. to ft.	SAND, GRAVEL, COBBLES	1	10
Sand/Filter pack: ☐ Yes ■ No Size of pack material in.	DECOMPOSED GRANITE	10	22
Materials placed from ft. to ft.	SOFT BROWN GRANITE	22	54
Surface Seal: Yes No To what depth? 18 ft.	SOFT GRAY GRANITE	54	56
Material used in seal BENTONITE	SOFT BROWN GRANITE	56	70
Did any strata contain unusable water? ☐ Yes ■ No	SOFT GRAY GRANITE	70 78	78 82
Type of water? Depth of strata	SOFT BROWN GRANITE BLACK AND WHITE GRANITE	82	146
Method of sealing strata off	GRAY GRANITE	146	165
Pump: Manufacturer's Name Type:	BLACK AND WHITE GRANITE	165	200
H.P Pump intake depth: ft. Designed flow rate: gpm			
Water Levels: Land-surface elevation above mean sea level ft. Stick-up of top of well casing ft. above ground surface			
Static water level 48 ft. below top of well casing Date 8/9/24			
Artesian pressure lbs. per square inch Date			
Artesian water is controlled by (cap, valve, etc.)			
Well Tests:			
Was a pumping test performed? ■ No □ Yes ⇒ by whom? Yield gpm with ft. drawdown after hrs.			
Yield gpm with ft. drawdown after hrs.			
Yield gpm with ft. drawdown after hrs.			
Recovery data (time = zero when pump is turned off – water level measured from well top to water level)			
Time Water Level Time Water Level Time Water Level			
Date of pumping test			
Bailer test gpm with ft. drawdown after hrs.			
Air test 5 gpm with stem set at 200 ft. for 1 hrs Date 8/9/24 Artesian flow gpm			
Temperature of water ° F Was a chemical analysis made? □ Yes ■ No	Start Date 8/8/24 Completed Date	8/9/24	
WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well			
construction standards. Materials used and the information reported above are true to my best knowledge and belief.			
■ Driller □ Trainee □ PE – Print Name SAM BEARDSLEE	Drilling Company BEARDSLEE DRILLING		
Signature	Address 409 E. ASTOR AVE		
License No. 2905	City, State, Zip COLVILLE, WA 99114		

Notice of Intent No. WE57378

Contractor's

Registration No. BEARDDL818MA

Date 8/20/24