

The Department of Ecology does NOT warrant the Data and/or the Information on this Well Report.

270238

WATER WELL REPORT

Original & 1st copy - Ecology, 2nd copy - owner, 3rd copy - driller

Construction/Decommission ("x" in circle)

- Construction
- Decommission ORIGINAL CONSTRUCTION Notice of Intent Number _____

PROPOSED USE: Domestic Industrial Municipal
 DeWater Irrigation Test Well Other

TYPE OF WORK: Owner's number of well (if more than one) _____
 New Well Reconditioned Method: Dug Bored Driven
 Deepened Cable Rotary Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 220 ft.
 Depth of completed well 220 ft.

CONSTRUCTION DETAILS
 Casing Welded 6" Diam. from +1 1/2 ft. to 149 ft.
 Installed: Liner installed 4" Diam. from -18 ft. to 220 ft.
 Threaded _____" Diam. from _____ ft. to _____ ft.

Perforations: Yes No
 Type of perforator used SKILLSAW
 SIZE of perfs 1/8 in. by 7 in. and no. of perfs 60 from 140 ft. to 220 ft.

Screens: Yes No K-Pac Location _____
 Manufacturer's Name _____
 Type _____ Model No. _____
 Diam. _____ Slot Size _____ from _____ ft. to _____ ft.
 Diam. _____ Slot Size _____ from _____ ft. to _____ ft.

Gravel/Filter packed: Yes No Size of gravel/sand _____
 Materials placed from _____ ft. to _____ ft.

Surface Seal: Yes No To what depth? 149 ft.
 Materials used in seal BENTONITE AND 6" CASING
 Did any strata contain unusable water? Yes No
 Type of water? _____ Depth of strata _____
 Method of sealing strata off _____

PUMP: Manufacturer's Name _____
 Type: _____ H.P. _____

WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
 Static level 94 ft. below top of well Date 8-9-07
 Artesian pressure _____ lbs. per square inch Date _____
 Artesian water is controlled by _____ (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made? Yes No If yes, by whom? _____
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
 Bailer test _____ gal./min. with _____ ft. drawdown after _____ hrs.
 Airstest 2 gal./min. with stem set at 220 ft. for 1 hrs.
 Artesian flow _____ g.p.m. Date _____
 Temperature of water _____ Was a chemical analysis made? Yes No

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Driller Engineer Trainee Name (Print) JON RICARD
 Driller/Engineer/Trainee Signature J Ricard
 Driller or Trainee License No. 2341

If trainee, licensed driller's _____
 Signature and License no. _____

CURRENT Notice of Intent No. W 255271

Unique Ecology Well ID Tag No. APT 046

Water Right Permit No. _____

Property Owner Name Harold Brennan

Well Street Address 2977 Marx Rd

City ADDY County: STEVENS

Location S 1/4 - 1/4 NE 1/4 Sec 12 Twn 34 R 37 EWMCircle or one WWM

Lat/Long: (s, r still REQUIRED) Lat Deg _____ Lat Min/Sec _____
 Long Deg _____ Long Min/Sec _____

Tax Parcel No. 1660630

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. Indicate all water encountered. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
CEMENTED GRAVELS	0	
CLAY, BRN, BOWLDERS		90
QUARTZ, DECOMPOSED	90	
TAN, WHT,		145
LIMESTONE, WHT, TAN	145	
GRN, HARD W/ 1 GPM		155
LIMESTONE, WHT, GRN HRD	155	190
FRACTURED AREAS W/ 2 GPM TOTAL	190	220

RECEIVED

AUG 24 2007

DEPARTMENT OF ECOLOGY
WELL DRILLING UNIT

AUG 21 03:40

RECEIVED

AUG 29 2007

DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE

Start Date 8-8-07 Completed Date 8-9-07

Drilling Company Clear Water Drilling Inc.
 Address P.O. Box 155
 City, State, Zip Malo, WA 99150
 Contractor's Registration No. CLEARWD953OK Date 8-9-07
 Ecology is an Equal Opportunity Employer. ECY 050-1-20 (Rev 4/01)