

WATER WELL REPORT

State of Washington Date Printed: 27-Oct-2015 Log No. 0
Construction / Decommission: Original
Construction Construction Notice

CURRENT
Notice of Intent No.: WE21992
Unique Ecology Well I.D. No BIO668
Water Right Permit Number:
OWNER: FERKA, ROBERT

OWNER ADD 4351-D HESSELTINE RD
VALLEY, WA 99181

Well Add 4351-D HESSELTINE RD

City: Valley, WA 99181 County: Stevens

Location: SE 1/4 NE 1/4 Sec 13 T 30 R 39 EW

Lat/Long: Lat Deg Lat Min/Sec
(s, t, r still) Long Deg Long Min/Sec
REQUIRED)

Tax Parcel No.: 2064800

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well)

NEW WELL

Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
Drilled 260 ft. Depth of completed well 260 ft.

CONSTRUCTION DETAILS:

Casing installed WELDED

Liner installed: PVC

4 " Dia from 20 ft. to 260 ft.

6 " Dia from +2 ft. to 30 ft.

" Dia from ft. to ft.

" Dia from ft. to ft.

Perforations: Yes Used In:

Type of perforator used SKILL SAW

SIZE of perforations 1/8 in. by 6 in.

60 Perforations from 200 ft. to 260 ft.

Perforations from ft. to ft.

Perforations from ft. to ft.

Screens: 0 K-Pac Location:

Manufacture's Name

Type: Model No

Diam. slot size: from ft. to ft.

Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel

Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.

Seal method: Material used in seal BENTONITE

Did any strata contain unusable water No

Type of water Depth of strata

Method of sealing strata off

PUMP: Manufacture's name

Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.

Static level 90 ft. below top of well Date 10/09/2015

Artesian Pressure lbs per square inch Date

Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield: gal/min with ft drawdown after

Yield: gal/min with ft drawdown after

Yield: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test:

Bailer test gal/min ft drawdown after hrs.

Air test 5 gal/min w/ stem set at 260 ft. for 1 hours

Artesian flow gpm Date

Temperature of water Was a chemical analysis made No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOP SOIL	0	1
SANDY CLAY COBBLES	1	16
BROKEN BASALT	16	22
DARK GRAY BASALT	22	231
FRACTURED W/WATER	231	243
DARK GRAY BASALT	243	260

RECEIVED

NOV 04 2015

Notes:

Work starte 10/07/2015


Complete 10/09/2015

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: SAM BEARDSLEE License No. 2905

Signature: 

If trainee, Licensed driller is: License No.:

Licensed Driller Signature

Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC.

Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99114

Phone: 509-684-2569

Toll Free: 800-533-6518

E-Mail: heidi@foglepump.com

FAX: 509-684-3032

WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4 Date Log Created: 10/27/2015