

# WATER WELL REPORT

State of Washington Date Printed: 21-Jul-2011 Log No.  
Construction / Decommission: Original 0  
Construction Construction Notice

**CURRENT**

Notice of Intent No.: W300314

Unique Ecology Well I.D. No. BCA852

Water Right Permit Number:

OWNER: DROUBAY, PRESTON

OWNER ADD 7504 191ST ST SW

LYNNWOOD, WA 98036

Well Add HERRON-GRIZZLEY LOOP RD

City: Republic, WA 99166

County: Ferry

Location: SW 1/4 SE 1/4 Sec 23 T 37 R 33 EW

Lat/Long:

Lat Deg

Lat Min/Sec

(s, t, r still

Long Deg

Long Min/Sec

REQUIRED)

Tax Parcel No.: 33723430001000

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) 1

NEW WELL

Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches

Drilled 300 ft. Depth of completed well 300 ft.

CONSTRUCTION DETAILS:

Casing installed WELDED

Liner installed: WELDED

6 " Dia from +2 ft. to 18 ft.

4 " Dia from 10 ft. to 300 ft.

" Dia from ft. to ft.

" Dia from ft. to ft.

Perforations: Yes Used In: LINER

Type of perforator used SKILL SAW

SIZE of perforations 1/8 in. by 7 in.

120 Perforations from 130 ft. to 300 ft.

Perforations from ft. to ft.

Perforations from ft. to ft.

Screens: 0 K-Pac Location:

Manufacture's Name

Type:

Model No

Diam. slot size: from ft. to ft.

Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel

Material placed from ft. to ft.

Surface seal: Yes To what depth 18 ft.

Seal method: Material used in seal BENT/CASING

Did any strata contain unusable water No

Type of water Depth of strata

Method of sealing strata off

PUMP: Manufacture's name

Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.

Static level 62 ft. below top of well Date 07/08/2011

Artesian Pressure lbs per square inch Date

Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield: gal/min with ft drawdown after

Yield: gal/min with ft drawdown after

Yield: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time: Water Level Time: Water Level Time: Water Level

Date of test:

Bailer test gal/min ft drawdown after hrs.

Air test 3 gal/min w/ stem set at 299 ft. for 1 hours

Artesian flow gpm Date

Temperature of water Was a chemical analysis made No

**CONSTRUCTION OR DECOMMISSION PROCEDURE**

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
LOAM	0	2
GRAVEL SAND CLAY	2	6
GRANITE DECOMPOSED BROWN	6	11
GRANITE BROWN SOFT	11	13
GRANITE BROWN MED	13	51
GRANITE GRAY MED HARD	51	170
GRANITE GRAY W/FILLITE MED	170	174
GRANITE GRAY MED HARD	174	257
GRANITE GRAY SOFT WET	257	258
GRANITE GRAY MED HARD	258	284
GRANITE GRAY HARD	284	300

Notes:

Work starte 07/07/2011

Complete 07/08/2011

**WELL CONSTRUCTION CERTIFICATION:**

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: AUDIE MCCURDY

License No.: 2690

Signature: 

If trainee, Licensed driller is.

License No.:

Licensed Driller Signature

**Drilling Company:**

NAME: FOGLE PUMP &amp; SUPPLY, INC.

Shop: REPUBLIC

ADDRESS: PO Box 456

Republic, WA 99166

Phone: 5097752878

Toll Free: 8008453500

E-Mail: leslie@foglepump.com

FAX: 5097750498

WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4

Date Log Created: 7/21/2011