

# WATER WELL REPORT

State of Washington Date Printed: 19-Oct-2007 Log No.  
Construction / Decommission: Original  
Construction Construction Notice 274730

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well)  
NEW WELL Method: ROTARY

DIMENSIONS Diameter of well: 6 inches  
Drilled 360 ft. Depth of completed well 360 ft.

CONSTRUCTION DETAILS: Casing installed WELDED  
Liner installed: PVC 6 " Dia from +2 ft. to 94 ft.  
4 " Dia from 40 ft. to 360 ft. " Dia from ft. to ft.

Perforations: Yes Used In: Liner  
Type of perforator used SKILL SAW  
SIZE of perforations 1/4 in. b 6 in.  
115 Perforation from 200 ft. to 360 ft.  
Perforation from ft. to ft.  
Perforation from ft. to ft.

Screens: No K-Pac Location  
Manufacture's Name  
Type: Model No  
Diam. slot size from ft. to ft.  
Diam. slot size from ft. to ft.

Gravel/Filter packed: No Size of Gravel  
Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.  
Seal method: Material used in seal BENTONITE  
Did any strata contain unusable water No  
Type of water Depth of strata  
Method of sealing strata off

PUMP: Manufacture's name  
Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.  
Static level 90 ft. below top of well Date 08/23/2007  
Artesian Pressure lbs per square inch Date  
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield gal/min with ft drawdown after  
Yield gal/min with ft drawdown after  
Yield gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test:

Bailer test gal/min ft drawdown after hrs.

Air test 9 gal/min w/ stem set at 359 ft. for 1 hours

Artesian flow gpm Date

Temperature of water Was a chemical analysis made No

CURRENT

Notice of Intent No.: WEO6709

Unique Ecology Well I.D. No ALN809

Water Right Permit Number:

OWNER: STEVENSON, CHARLES A

OWNER ADD 32321 226TH AVE SE  
KENT, WA 98042

Well Add BURTES DR

City: Kettle Falls, WA 99141 County: Stevens

Location: SE 1/4 SE 1/4 Sec 9 T 35 R 34E EW

Lat/Long: Lat Deg Lat Min/Sec  
(s, t, r still) Long Deg Long Min/Sec  
REQUIRED)

Tax Parcel No.: 73509410002400

## CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
FINE SAND W/ CLAY LAYERS BR	0	70
CLAY BROWN W/ SILT MOIST	70	89
LIMESTONE GRAY MED	89	221
FRAC W/ 3 GPM	221	222
LIMESTONE GRAY MED	222	275
LIMESTONE BLACK SOFT W/ 6 GPM	275	279
LIMESTONE BLACK QUARTZ	279	356
LIMESTONE GRAY MED	356	360

RECEIVED  
OCT 29 2007

Notes:

DEPARTMENT OF ECOLOGY  
EASTERN REGIONAL OFFICE

Work starte 08/21/2007 Complete 08/23/2007

## WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: DAVID MEYER License No.: 2427

Signature: 

If trainee, Licensed driller is: License No.:

Licensed Driller Signature

## Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99114

Phone: 509-684-2569 Toll Free: 800-533-6518

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4 Date Log Created: 08/27/2007