

WATER WELL REPORT

State of Washington Date Printed 28-Aug 2003 Log No 26103
 Construction/Decommission Original Construction
 Construction Notice of Intent # 138368

CURRENT

Notice of Intent No W173895
 Unique Ecology Well I D No AHT222
 Water Right Permit Number

OWNER PUGH BRIAN

OWNER ADDR PO BOX 832 FRIDAY HARBOR WA 98250

Well Street Address Lot 9 First Thought River

City Laurier WA 99146 County FERRY

Location NE 1/4 SW 1/4 Sec 14 T 40 R 36E EWM

Lat/Long (s t r still) Lat Deg Lat Min/Sec

REQUIRED Long Deg Long Min/Sec

Tax Parcel No 64014500009000

PROPOSED USE DOMESTIC

TYPE OF WORK Owners s Well Number (If more than one well) 1
 NEW WELL Method ROTARY

DIMENSIONS Diameter of well 6 inches
 Drilled 80 ft Depth of completed well 78 ft

CONSTRUCTION DETAILS Casing installed WELDED
 6 Dia from +2 ft to 73 ft
 Dia from ft to ft
 Dia from ft to ft

Perforations No Used In
 Type of perforator used
 SIZE of perforations in by in
 Perforations from ft to ft
 Perforations from ft to ft
 Perforations from ft to ft

Screens Yes K Pac Location 72
 Manufacture s Name JOHNSON
 Type SLOTTED Model No STAINLESS
 Diam 5 slot size 014 from 73 ft to 78 ft
 Diam slot size from ft to ft

Gravel/Filter packed No Size of Gravel
 Material placed from ft to ft

Surface seal Yes To what depth 18 ft
 Seal method Material used in seal BENTONITE
 Did any strata contain unusable water? No
 Type of water Depth of strata
 Method of sealing strata off

PUMP Manufacture s name
 Type H P 0

WATER LEVELS Land surface elevation above mean sea level 0 ft
 Static level 40 ft below top of well Date 08/18/2003
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by

WELL TESTS Drawdown is amount water level is lowered below static level
 Was a pump test made? No If yes by whom?
 Yield gal/min with ft drawdown after
 Yield gal/min with ft drawdown after
 Yield gal/min with ft drawdown after
 Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)
 Time Water Level Time Water Level Time Water Level
 Date of test
 Bailer test gal/min ft drawdown after hrs
 Air test 20 gal/min w/ stern set at 77 ft for 1 hours
 Artesian flow gpm Date
 Temperature of water Was a chemical analysis made? No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation Describe by color character size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated Show at least one entry for each change in formation

Material	From	To
TOPSOIL	0	2
GRAVEL W/SAND	2	24
CLAY BROWN	24	45
SAND BROWN FINE	45	70
SAND COARSE	70	80

SEP - 5 2003

Notes

Work started 08/18/2003 Completed 08/18/2003

WELL CONSTRUCTION CERTIFICATION

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards Materials used and the information reported are true to my best knowledge and belief

☒ Driller ☐ Engineer ☐ Trainee

Name DAVID MEYER License No 2427

Signature David Meyer

If trainee Licensed driller is License No

Licensed Driller Signature

Drilling Company

NAME FOGLE PUMP & SUPPLY INC Shop COLVILLE

ADDRESS 316 W 5TH

Colville WA 99114

Phone 509-684 2569 Toll Free 800 533-6518

E Mail jrs@foglepump.com

FAX 509-684 3032 WEB Site www.foglepump.com

Contractor s
 Registration No FOGLEPS095L4 Date Log Created 08/28/2003

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.