

WATER WELL REPORT

43042

STATE OF WASHINGTON

Start Card No. W58369
 Unique Well I.D. # ABI938
 Water Right Permit No.

(1) OWNER: Name NELSON, DONALD Address 3102 CASCADE TRAIL NE BREMERTON,, WA 99114-
 (2) LOCATION OF WELL: County STEVENS - NW 1/4 SW 1/4 Sec 20 T 39 N., R 37E WM
 (2a) STREET ADDRESS OF WELL (or nearest address),

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well 1
 (If more than one)
 NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
 Drilled 360 ft. Depth of completed well 360 ft.

(6) CONSTRUCTION DETAILS:
 Casing installed: 6 " Dia. from +1 ft. to 30 ft.
 WELDED 4 " Dia. from 9 ft. to 360 ft.
 " Dia. from ft. to ft.

Perforations: YES

Type of perforator used SKILL SAW
 SIZE of perforations 1/8 in. by 6 in.
 perforations from 220 ft. to 360 ft.
 perforations from ft. to ft.
 perforations from ft. to ft.

Screens: NO

Manufacturer's Name
 Type Model No.
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel
 Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.
 Material used in seal BENTONITE
 Did any strata contain unusable water? NO
 Type of water? Depth of strata ft.
 Method of sealing strata off CASING

(7) PUMP: Manufacturer's Name
 Type SUBMERSIBLE H.P.

(8) WATER LEVELS: Land-surface elevation
 above mean sea level ... ft.
 Static Level 25 ft. below top of well Date 07/19/95
 Artesian Pressure lbs. per square inch Date
 Artesian water controlled by CAP

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?
 Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time Water Level Time Water Level Time Water Level


Date of test / /

Bailer test gal/min. ft. drawdown after hrs.
 Air test 3 gal/min. w/ stem set at 359 ft. for 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
DIRT LARGE BROKEN ROCK	0	14
LIMESTONE QUARTZ GRAVEL	14	27
GRAY LIMESTONE	27	29
GRAY BLACK LIMESTONE	29	90
FRACTURED GRAY LIMESTONE	90	91
LIMESTONE QUARTZ STRINGERS	91	235
FRACTURED GRAY LIMESTONE	235	236
GRAY BLACK LIMESTONE	236	325
FRACTURED GRAY MEDIUM	325	326
GRAY BLACK LIMESTONE	326	360
	360	



Work started 07/17/95

Completed 07/19/95

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC.

(Person, firm, or corporation) (Type or print)

ADDRESS 316 W 5TH

[SIGNED] Terry D. Conkling License No. 1895

Contractor's

Registration No. FOGLEPS095L4

Date 07/19/95