File Original and First Copy with Department of Ecology Second Copy — Owner's Copy Third Copy — Driller's Copy

Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes \_\_\_\_

## **WATER WELL REPORT**

Start Card No. W 051477

UNIQUE WELL I.D. # ABM 726

STATE OF WASHINGTON

Water Right Permit No.

(1) OWNER: Name Joseph Menard	Address PO Box 1222 Turn Turn, WA 99034
LOCATION OF WELL: county Stevens	1/4 Sec 20 T. 27 N. R 40 WI
(2a) STREET ADDRESS OF WELL (or nearest address)	
(3) PROPOSED USE: Proposition Industrial Municipal	
☐ DeWater Test Well ☐ Other ☐	and the kind and nature of the material in each stratum penetrated, with at least one entry for each
(4) TYPE OF WORK: Owner's number of well (# more than one)	change of information.
Abandoned   New well   Method: Dug   Bored	
Deepened ☐ Cable ☐ Driven ☐ Reconditioned ☐ Rotary ☐ Jetted ☐	
(5) DIMENSIONS: Diameter of well 6 In	med coarse said & builders 2 30 68
Drilled 150 feet. Depth of completed well 150	_ n. Fine sands 68 150
(6) CONSTRUCTION DETAILS:  Casing installed: 6 - Diam from +2 ft. to 118	
Welded	_ ft.
Liner installed   Diam from 10 ft. to 120	- ".
Perforations: Yes No III	
SIZE of perforations in. by	in.
perforations from ft. to	****
perforations fromft. to	_,,
perforations from ft. to	n
Screens: Yes No 🗌	
Manufacturer's Name	_
Type PVC Model No	
am. 4 Slot size 10 from 120 ft. to 150	
Diam. Slot size from ft. to	_t
Gravel packed: Yes No Size of gravel 10-20	
Gravel placed from 130 ft. to 150	_n
Surface seal: Yes 🕒 No 🗌 To what depth?18	_ n
Material used in seal <u>Pentonite</u>	OCT 18 1994 111
Oid any strata contain unusable water? Yes No	
Type of water? Depth of strata Method of sealing strata off	
webco or searing strate on	
(7). PUMP: Manufacturer's Name	710
Type:	
(8) WATER LEVELS: Land-surface elevation above mean sea level	e. Work Sturred 9-20 , 19 Completed 9-23 , 19 94
Static level 80 ft. below top of well Date 9-23-94	WELL CONSTRUCTOR CERTIFICATION:
Artesian pressure	
Artesian water is controlled by(Cap, valve, etc.)	i constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	the information reported above are true to my best knowledge and belief.
Was a pump test made? Yes No I H yes, by whom?	NAME Minden Drilling Inc
Yield:gal./min. with1. drawdown after	
	" Address N 31621 Cedar Deer Park, WA 99006
16 21 30	(Signed) Rodger Hiat / License No. 2216
Recovery data (time taken as zero when pump turned off) (water level measured from top to water level)	(Signed) / 00 gc License No. 2216
Time Water Level Time Water Level Time Water Le	Contractor's
	Registration
	No. MTNDFDT09019 Date 9-27 1994
Date of test	(USE ADDITIONAL SHEETS IF NECESSARY)
Bailer teet gal./min, with ft. drawdown after	hrs.
Airtest 20 gal./min, with stem set at 148 ft. for 30 mi	The Ecology is an Equal Opportunity and Affirmative Action employer. For spe-
Artesian flowg.p.m. Date	cial accommodation needs, contact the Water Resources Program at (206 407-6600. The TDD number is (206) 407-6006.
Temperature of water Was a chammal applicate mode? Vos No.	TO TOO THE TEN HUMBER IS (EVO) TO TOO .

No 🗌