

WATER WELL REPORT

Start Card No
55202

Inv > 922128

STATE OF WASHINGTON

Water Right Permit No

(1) OWNER: Name Tim Pennels/Ellie LaFraugh Address 2012 S. 314th #265 Everett, WA

(2) LOCATION OF WELL: County Ferry NE NW 22 36 33 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ DeWater ☐ Test Well ☐ Other

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
Abandoned ☐ New well ☒ Method: ☐ Dug ☐ Bored ☐
☐ Deepened ☐ Cable ☐ Driven ☐
☐ Reconditioned ☐ Rotary ☒ Jetted

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 220 feet. Depth of completed well 220 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 ft. Diam. from + ft. to 84 ft.
Welded ☒ Diam. from + ft. to 84 ft.
Liner installed ☐ Diam. from + ft. to 84 ft.
Threaded ☐ Diam. from + ft. to 84 ft.

Perforations: Yes ☐ No ☒
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☐ No ☒
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ from _____ ft. to _____ ft.
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☒ No ☐ To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type _____ HP _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 30 ft below top of well Date 4/10/92
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap. valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
Time Water Level Time Water Level Time Water Level

Date of test _____


Bailer test 15 gal./min. with _____ ft. drawdown after 1.0 hrs.
Artest 15 gal./min. with stem seal at _____ ft. for _____ hrs.

Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation. Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Overburden	0	1
Sand-brown, fine, gravel	1	5
Boulders, gravel, fine sand	5	11
Clay-compacted, gravel	11	35
Clay-blue hardpan	35	84
Granite-salt & pepper, med. hard	84	189
Granite-salt & pepper 1 gpm	189	211
Granite-salt & pepper, med. 15 gpm	211	220



Work started 4/8/92, 19. Completed 4/10/92, 19.

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Eagle Pump & Drilling West
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
P.O. Box 147, Malo WA 99150

Address _____

(Signed) Richard Brown (BY DRS) License No. 1238
(WELL DRILLER)

Contractor's Registration #PS 895 L4 Date 4/18/92
No. _____ 19.

(USE ADDITIONAL SHEETS IF NECESSARY)