

*J. E. G. G.*

**NORTHEAST TRI COUNTY HEALTH DISTRICT  
DIVISION OF ENVIRONMENTAL HEALTH  
ON-SITE SEWAGE SYSTEM PERMIT # 5001062**

5001062  
32 - 35 - 40

Miko & Christine Welfel is hereby authorized to utilize a sewage disposal system at  
TAX #12 & TAX #13

Section: 32 Township: 35 Range: 40 Parcel #: 2684133 & 2684135

in accordance with the plans and specifications approved by the District Health Officer on file in this office.

Prior to any major repairs, replacements or alterations to the system a permit shall be obtained from the Northeast Tri County Health District (Division of Environmental Health).

This permit is issued and may be revoked by the Northeast Tri County Health District Health Officer by authority of WAC 246-272, and Northeast Tri County Health District Regulations established by the Board of Health pursuant to RCW 70.05.

Additional permits from other jurisdictions or agencies may be necessary for this project. It is the responsibility of the applicant to acquire said permit (s), and comply with all applicable rules, regulations and/or ordinances.

*E. Welfel*

\_\_\_\_\_  
District Health Officer

Date Issued: 04/16/2001

**PERMIT INSTRUCTIONS**

STRUCTURE TYPE: Single Family Residence  
NUMBER OF BEDROOMS: 3  
DESIGN FLOW (gal/day): 360  
TYPE OF SYSTEM: New  
SYSTEM DESIGN: Conventional Gravity  
SEPTIC TANK CAPACITY (gal): 1000  
REASON SYSTEM DESIGN: Adequate soils

DFLF/BED DIMENSIONS: 200'  
TRENCH DEPTH (inches): 36  
TRENCH WIDTH (inches): 36  
APPURTANENCES:  
PUMP CHAMBER (y/n): N  
PUMP CHAMBER GALLONS: 0

SPECIAL PERMIT INSTRUCTIONS:

FINAL INSPECTION DATE: 6/26/01

INITIALS: *JH*

\*\* SEE REVERSE FOR AS BUILT DRAWING

SP 8668

FINAL AS-BUILT DRAWING - PERMIT # 500062

DATE OF FINAL INSPECTION 10/26/01 BY JH

1000 gallon tank  
Installed Dick Stewart

