

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

Start Card No. W62402
 Unique Well I.D. # ACC885
 Water Right Permit No.

STATE OF WASHINGTON

(1) OWNER: Name CHRISTIE, LARRY Address 325 E. 4TH ST COLVILLE, WA 99114-

(2) LOCATION OF WELL: County STEVENS - E 1/4 SW 1/4 Sec 33 T 35 N., R 39E WM
 (2a) STREET ADDRESS OF WELL (or nearest address),

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well (If more than one) 1
 Method: ROTARY
 NEW WELL

(5) DIMENSIONS: Diameter of well 6 inches
 Drilled 420 ft. Depth of completed well 420 ft.

(6) CONSTRUCTION DETAILS:
 Casing installed: 6 " Dia. from +2 ft. to 22 ft. WELDED 4 " Dia. from 15 ft. to 420 ft.
 " Dia. from ft. to ft.

Perforations: YES
 Type of perforator used SKILL SAW
 SIZE of perforations 1/4 in. by 6 in.
 24 perforations from 300 ft. to 320 ft.
 24 perforations from 360 ft. to 380 ft.
 24 perforations from 400 ft. to 420 ft.

Screens: NO
 Manufacturer's Name
 Type Model No.
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel packed: NO
 Gravel placed from ft. to ft. Size of gravel ft.

Surface seal: YES To what depth? 19 ft.
 Material used in seal BENTONITE
 Did any strata contain unusable water? NO
 Type of water? Depth of strata ft.
 Method of sealing strata off CASING

(7) PUMP: Manufacturer's Name Type NONE H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
 Static Level 18 ft. below top of well Date 09/22/95
 Artesian Pressure lbs. per square inch Date
 Artesian water controlled by CAP

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?
 Yield: gal./min with ft. drawdown after hrs.

Recovery data
 Time Water Level Time Water Level Time Water Level

Date of test / /
 Bailer test gal/min. ft. drawdown after hrs.
 Air test 2 gal/min. w/ stem set at 419 ft. for 1 hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

| MATERIAL | FROM | TO |
|--------------------------------|------|-----|
| TOPSOIL | 0 | 3 |
| GRAVEL BROKEN ROCK | 3 | 14 |
| CLAY BLUE BROKEN ROCK | 14 | 24 |
| SLATE GRAY WATER BEARING | 24 | 40 |
| SLATE GRAY MEDIUM | 40 | 63 |
| SLATE GRAY WATER BEARING | 63 | 87 |
| SLATE GRAY HARD | 87 | 95 |
| SLATE GRAY SOFT | 95 | 109 |
| SLATE GRAY HARD | 109 | 166 |
| SLATE GRAY MEDIUM | 166 | 257 |
| SLATE GRAY SOFT | 257 | 274 |
| SLATE QUARTZ HARD | 274 | 288 |
| LIMESTONE QUARTZ SOFT | 288 | 328 |
| LIMESTONE QUARTZ MEDIUM | 328 | 337 |
| LIMESTONE QUARTZ WATER BEARING | 337 | 360 |
| LIMESTONE QUARTZ SOFT | 360 | 420 |

Work started 09/21/95 Completed 09/22/95

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC.
 (Person, firm, or corporation) (Type or print)

ADDRESS 316 W 5TH

[SIGNED] *Ron Hume* License No. 2258

Contractor's Registration No. FOGLEPS095L4 Date 09/22/95