WATER WELL REPORT

State of Washington Date Printed: 27-Aug-2003 Log No. 26703

Construction/Decommission: Original Construction
Construction Notice of Intent #:

CURRENT
Notice of Intent No.: W173868
Unique Ecology Well I.D. No.: AHT220
Water Right Permit Number:

OWNER: BLANKENSHIP, DENISE
OWNER ADDR: PO BOX 286 ADDY, WA 99101
Well Street Address: 40 1ST THOUGHT LOOP
City: Laurier, WA 99146 County: FERRY
Location: NW 1/4 SW 1/4 Sec 14 T 40 R 36E EWM
Lat/Long: (s, t, r still REQUIRED) Lat Deg Lat Min/Sec Long Deg Long Min/Sec
Tax Parcel No.:

PROPOSED USE: DOMESTIC

TYPE OF WORK Owners's Well Number: (If more than one well) 1
NEW WELL Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
Drilled 115 ft. Depth of completed well 108 ft.

CONSTRUCTION DETAILS:
Casing installed: WELDED
6 " Dia from +2 ft. to 103 ft.
" Dia from ft. to ft.
" Dia from ft. to ft.

Liner installed:
" Dia from ft. to ft.

Perforations: No Used In:
Type of perforator used:
SIZE of perforations in. by in.
Perforations from ft. to ft.
Perforations from ft. to ft.
Perforations from ft. to ft.

Screens: Yes K-Pac Location: 102
Manufacture's Name: JOHNSON
Type: SLOTTED Model No. STAINLESS
Diam. 5 slot size: .012 from 103 ft. to 108 ft.
Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel
Material placed from ft. to ft.

Surface seal: Yes To what depth 18 ft.
Seal method: Material used in seal: BENTONITE
Did any strata contain unusable water?: No
Type of water: Depth of strata
Method of sealing strata off

PUMP: Manufacture's name
Type: H.P. 0

WATER LEVELS: Land-surface elevation above mean sea level: 0 ft.
Static level 30 ft. below top of well Date 08/13/2003
Artesian Pressure: lbs per square inch Date
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made? No If yes, by whom?
Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test:
Bailer test gal/min ft drawdown after hrs.
Air test 20 gal/min w/ stem set at 107 ft. for 1 hours
Artesian flow gpm Date:
Temperature of water Was a chemical analysis made? No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOPSOIL	0	2
CLAY BOULDERS	2	26
SAND/GRAVEL CLAY BROWN	26	65
SAND CLAY BLUE	65	90
SAND CLAY BROWN	90	102
SAND GRAVEL	102	110
CLAY BROWN	110	115

Notes:

Work started 08/12/2003 Completed 08/13/2003

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☑ Driller ☐ Engineer ☐ Trainee

Name: DAVID MEYER License No.: 2427
Signature: David Meyer

If trainee, Licensed driller is: License No.:
Licensed Driller Signature:

Drilling Company:
NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE
ADDRESS: 316 W. 5TH
Colville, WA 99114
Phone: 509-684-2569 Toll Free: 800-533-6518
E-Mail: jrs@foglepump.com
FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's Registration No.: FOGLEPS095L4 Date Log Created: 08/27/2003