The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

(1) **OWNER:** Name Bill Ripper Address Newport Wash

(2) **LOCATION OF WELL:** County Pend Oreille NW ¼ SW ¼ ¼ Sec 28 T. 35 N., R. 4/4 W.M.

Bearing and distance from section or subdivision corner

PROPOSED USE: Domestic ☑ Industrial ☐ Municipal ☐
Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) .....
New well ☑ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☑ Driven ☐
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 67 ft. Depth of completed well 67 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from 1 ft. to 67 ft.
Threaded ☐ ..... " Diam. from ..... ft. to ..... ft.
Welded ☑ ..... " Diam. from ..... ft. to ..... ft.

Perforations: Yes ☐ No ☑
Type of perforator used .....
SIZE of perforations ..... in. by ..... in.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.
..... perforations from ..... ft. to ..... ft.

Screens: Yes ☑ No ☐
Manufacturer's Name Cook's
Type Stainless steel Model No. 304
Diam. ..... Slot size 14 from 67 ft. to 62 ft.
Diam. ..... Slot size ..... from ..... ft. to ..... ft.

Gravel packed: Yes ☐ No ☑ Size of gravel: .....
Gravel placed from ..... ft. to ..... ft.

Surface seal: Yes ☑ No ☐ To what depth? 18 ft.
Material used in seal .....
Did any strata contain unusable water? Yes ☐ No ☑
Type of water? ..... Depth of strata .....
Method of sealing strata off .....

(7) PUMP: Manufacturer's Name .....
Type: ..... H.P. .....

(8) WATER LEVELS: Land-surface elevation above mean sea level .... ft.
Static level 47 ft. below top of well Date .....
Artesian pressure ..... lbs. per square inch Date .....
Artesian water is controlled by ..... (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☑ If yes, by whom? .....
Yield: ..... gal./min. with ..... ft. drawdown after ..... hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 7-10-85
test 3 gal./min. with ..... ft. drawdown after ..... hrs.
Artesian flow ..... g.p.m. Date .....
Temperature of water ..... Was a chemical analysis made? Yes ☐ No ☑

8/5/85

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
0 to 12 Sand		
12 to 30 Sand & Boulders		
30 to 63 Cemented Sand		
63 to 67 Clean Sand from	Water 63	67

RECEIVED
AUG - 3 1985
DEPARTMENT OF ECOLOGY
SPOKANE REGIONAL OFFICE

Work started 6-25, 19 85 Completed 7-10, 19 85

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME Carl Pixley Well Drilling
(Person, firm, or Corporation) (Type or print)

Address Post Falls Idaho

[Signed] Carl Pixley
(Well Driller)

License No. 0397 Date 7-31, 19 85

(USE ADDITIONAL SHEETS IF NECESSARY)

S. F. No. 7356—OS—(Rev. 4-71)
ECY-070-28