

SR 113/

10174

27-40-34

Septic Tank	1000	Gals.
Disp. Field	150	L.F.T
Other		
☒ New ☐ Repair		

Renewed ✓
 9/13/96
 Rec # 014893
 \$30.

NORTHEAST TRI-COUNTY HEALTH DISTRICT
Division of Environmental Health
 (X) Colville Office, Box 270, Phone 684-2262
 () Newport Office, Box 490, Phone 447-3131
 () Republic Office, Box 584, Phone 775-3161

Permit No. C10174

Fee Paid \$200.00

Receipt No. 0012259

- backfill & grade trenches; maintain 2' max cover over gravel
- place long sanitary tee on tank outlet, short one on inlet
- abandon any alternate form of wastewater disposal.
- place fabric atop gravel

Steve Greene

is hereby authorized to utilize a sewage disposal

system at Tax #7 Sec 27 Twp 40 Rng 36 and in accordance
 with the plans and specifications approved by the District Health Officer on file in this office.

Any major repairs or alterations to the system shall be reported to the Northeast Tri-County Health District (Division of Environmental Health) for approval PRIOR to construction.

This permit is issued and may be revoked by the Northeast Tri-County Health District Health Officer by the authority of WAC 246-272, and Rules and Regulations established by the Board pursuant to RCW 70.0.

Witness my hand and seal this 4th day of October, 19 95

Date of Inspection 10-2-97 B. Mergen
 D.P. Form No. 6134-B

[Signature]
 District Health Officer

10.2.97 as-built

