

WATER WELL REPORT

State of Washington Date Printed 01 Jul 2003 Log No
Construction/Decommission Original Construction 18703
Construction Notice of Intent # 134595

CURRENT

Notice of Intent No W170270
Unique Ecology Well I D No AKW803
Water Right Permit Number

OWNER ANTRIM PAUL

OWNER ADDR 38 HART RD OROVILLE WA 98844

Well Street Address 38 HARD RD

City Oroville WA 98844 County OKANOGAN

Location SW 1/4 SW 1/4 Sec 28 T 40 R 27E EWM

Lat/Long Lat Deg Lat Min/Sec

(s t r still) Long Deg Long Min/Sec

Tax Parcel No 6450040005

PROPOSED USE DOMESTIC

TYPE OF WORK Owners s Well Number (If more than one well) 1

NEW WELL Method ROTARY

DIMENSIONS Diameter of well 6 inches
Drilled 138 ft Depth of completed well 138 ft

CONSTRUCTION DETAILS

Casing installed WELDED

Liner installed

4 Dia from +1 ft to 128 ft

6 Dia from +2 ft to 129 ft

Dia from ft to ft

Dia from ft to ft

Perforations No Used In

Type of perforator used

SIZE of perforations in by in

Perforations from ft to ft

Perforations from ft to ft

Perforations from ft to ft

Screens Yes K Pac Location

Manufacture s Name GOSSCO

Type PREPACK Model No

Diam 5 slot size 10 from 128 ft to 138 ft

Diam slot size from ft to ft

Gravel/Filter packed No Size of Gravel

Material placed from ft to ft

Surface seal Yes To what depth 18 ft

Seal method Material used in seal BENTONITE

Did any strata contain unusable water? No

Type of water Depth of strata

Method of sealing strata off

PUMP Manufacture s name

Type H P 0

WATER LEVELS Land surface elevation above mean sea level 0 ft

Static level 25 ft below top of well Date 06/24/2003

Artesian Pressure lbs per square inch Date

Artesian water controlled by

WELL TESTS Drawdown is amount water level is lowered below static level

Was a pump test made? Yes If yes by whom? JON RICARD/FP&S

Yield 15 gal/min with 20 ft drawdown after 15

Yield gal/min with ft drawdown after

Yield gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal/min ft drawdown after hrs

Air test gal/min w/ stem set at ft for hours

Artesian flow gpm Date


Temperature of water Was a chemical analysis made? No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation Describe by color character size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated Show at least one entry for each change in formation

Material From To

BROWN SAND MEDIUM GRAVEL COBBLES	0	24
BROWN SAND MEDIUM GRAVEL WET	24	28
GRAY CLAY	28	75
SILT CLAY GRAY/WET	75	102
GRAY CLAY	102	112
SILT GRAY W/WATER	112	138



Notes

Work started 06/23/2003

Completed 06/24/2003

WELL CONSTRUCTION CERTIFICATION

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards Materials used and the information reported are true to my best knowledge and belief

☒ Driller ☐ Engineer ☐ Trainee

Name JON RICARD License No 2341

Signature Jon Ricard

If trainee Licensed driller is License No

Licensed Driller Signature

Drilling Company

NAME FOGLE PUMP & SUPPLY INC Shop REPUBLIC

ADDRESS PO Box 456

Republic WA 99166

Phone 5097752878 Toll Free 8008453500

E Mail wlb@foglepump.com

FAX 5097750498 WEB Site www.foglepump.com

Contractor s

Registration No FOGLEPS095L4 Date Log Created 07/01/2003