

00001

17

11

07065

15-35-39

Septic Tank 1000 Gals.
Disp. Field 220 L.F.T.
Other _____
() New _____
(x) Repair _____

NORTHEAST TRI-COUNTY HEALTH DISTRICT
Division of Environmental Health

- (x) Colville Office, Box 270, Phone 684-2262
- () Newport Office, Box 490, Phone 447-3131
- () Republic Office, Box 584, Phone 775-3161

Permit No. 7065

Fee Paid \$150.00

Receipt No. 1143

Virginia DesChamps is hereby authorized to utilize a sewage disposal
Tax #55
system at Sec 15 Twp 35 Rng 39 and in accordance
with the plans and specifications approved by the District Health Officer on file in this office.

Any major repairs or alterations to the system shall be reported to the Northeast Tri-County Health District (Division of Environmental Health) for approval PRIOR to construction.

This permit is issued and may be revoked by the Northeast Tri-County Health District Health Officer by the authority of WAC 248-96, and Rules and Regulations established by the Board pursuant to RCW 70.05.

Witness my hand and seal this 29th day of April, 19 92


Date of Inspection 5/4/92 M. Nudalen Tim Allen MD

4/29/92 - left note for Mike Ressa
to leave outlet side of new ST
uncovered to see if still leaking
when it fills back up. (It was
leaking around outlet pipe
yesterday, it has since been
pumped out to allow for
better sealing & d.f. installation.)

5/4/92 - leaking outlet pipe
fixed. MM

As Built 4/29/92 MM

N →



3

26'



existing 600-gal (?)
concrete tank

new 1,000-gal. concrete
tank

18'

10'

