

30828

WATER WELL REPORT

STATE OF WASHINGTON

Water Right Permit No.

Start Card No. W19968
UNIQUE WELL I.D. # AAK877

(1) OWNER: Name Mr. Robert E. Harmon Address 2132 Pudding Road, Potosi, Mo. 64901

LOCATION OF WELL: County Stevens E 1/4, N 1/2, 1/4 Sec 6, T. 29 N. R. 40 E. 405

(2a) STREET ADDRESS OF WELL (or nearest address) Skenter Road, Springdale, Wash. 99173

(3) PROPOSED USE: Domestic Industrial Municipal
 Irrigation Test Well Other
 DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned New well Deepened Reconditioned
Method: Dug Cable Rotary Bored Driven Jetted

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 324 feet. Depth of completed well 324 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from 0 ft. to 324 ft.
Welded Liner installed Threaded
Diam. from _____ ft. to _____ ft.

Perforations: Yes No
Type of perforator used _____
SIZE of perforations 1 in. by 1/4 in.
_____ perforations from 25 ft. to 33 ft.

Screens: Yes No
Manufacturer's Name _____
Type _____ Model No. _____
Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes No Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes No To what depth? 18 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes No
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 12 ft. below top of well Date _____
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes No If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)
Time Water Level Time Water Level Time Water Level

Date of test _____
Bailer test 30 gal./min. with 0 ft. drawdown after 1 hrs.
Airtest _____ gal./min. with stem set at _____ ft. for _____ hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes No

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
topsoil	0'	1'
Sand and gravel	1'	7'
clay	7'	20'
Sand and gravel	20'	23'
Sand, gravel, water	23'	33'
clay	33'	110'
quick sand and clay	110'	324'

JUN 15 1995

Work Started 5-5 19. Completed 5-20 1995

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Howard's well drilling
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address PO Box 153

(Signed) Ed Howard Jr License No. 1902
(WELL DRILLER)

Contractor's Registration No. Howard 099 JC Date 5-95 1995

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

